

TOLEDO BEND PROJECT JOINT OPERATION

450 Spur 135, Burkeville, TX 75932 59839 Hwy 191, Anacoco, LA 71403
409/565-2273 337/286-5244 (Office)
337/286-5253 (Message)

ADVISORY # 11

DATE: Saturday, June 15, 2024

TOLEDO BEND RESERVOIR – WATER RELEASES

AS OF TIME: 07:45 hrs

RESERVOIR ELEV: 172.20 FT. MSL

SPILLWAY RELEASES HAVE CHANGED FROM 11000 cfs TO 5000 cfs

IN ACCORDANCE WITH THE GUIDE FOR SPILLWAY GATE OPERATIONS IN THE LICENSE APPROVED BY FERC FOR TOLEDO BEND RESERVOIR, CURRENT RELEASES ARE NOTED BELOW:

SPILLWAY GATES

Number of Gates	Opened (Feet)
05	01

GENERATORS

Generator #	Current Status
1	24 hrs at 8160 cfs
2	24 hrs at 6295 cfs

TOTAL RELEASES

	(CFS)
SPILLWAY	5000
GENERATORS	14455
TOTAL	19455

Up-to-date reservoir elevations and releases as well as links to specific river gauges may be obtained from SRA's websites: www.srala-toledo.com , www.sratx.org and www.setexasrain.org. Information on specific river gages can be obtained from the National Weather Service at the following website: <http://www.weather.gov/wgrfc> and from the USGS at the following websites: <http://tx.waterdata.usgs.gov> or <https://la.waterdata.usgs.gov>.

Actual flooding conditions may vary significantly from the alert based on new or changed conditions; advanced alerts of changed conditions may not be possible.