

TOLEDO BEND PROJECT JOINT OPERATION

450 Spur 135, Burkeville, TX 75932 59839 Hwy 191, Anacoco, LA 71403
409/565-2273 337/286-5244 (Office)
337/286-5253 (Message)

ADVISORY # 13

DATE: **Friday, June 28, 2024**

TOLEDO BEND RESERVOIR – WATER RELEASES

AS OF TIME: **07:30 hrs**

RESERVOIR ELEV: **172.14** FT. MSL

SPILLWAY RELEASES HAVE CHANGED FROM **11000** cfs TO **5000** cfs

IN ACCORDANCE WITH THE GUIDE FOR SPILLWAY GATE OPERATIONS IN THE LICENSE APPROVED BY FERC FOR TOLEDO BEND RESERVOIR, CURRENT RELEASES ARE NOTED BELOW:

SPILLWAY GATES

Number of Gates	Opened (Feet)
05	01

GENERATORS

Generator #	Current Status
1	24 hrs at 7660 cfs
2	24 hrs at 5931 cfs

TOTAL RELEASES

	(CFS)
SPILLWAY	5000
GENERATORS	13591
TOTAL	18591

Up-to-date reservoir elevations and releases as well as links to specific river gauges may be obtained from SRA's websites: www.srala-toledo.com, www.sratx.org and www.setexasrain.org. Information on specific river gauges can be obtained from the National Weather Service at the following website: <http://www.weather.gov/wgrfc> and from the USGS at the following websites: <http://tx.waterdata.usgs.gov> or <http://la.waterdata.usgs.gov>.

Actual flooding conditions may vary significantly from the alert based on new or changed conditions; advanced alerts of changed conditions may not be possible.